



MUNICIPAL CORPORATION CHANDIGARH
Public Health Laboratory at Water Works Sector 39.

TEST - REPORT

Not for legal use

Ref. No. & Date :- No. 01-03/JNVCHD/2021-22/225 Dated 17.06.2021
Issued to :- The Principal,
Jawahar Navodaya Vidyalaya,
Sector 25 (West), Chandigarh
Quantity of sample :- Approximate 1200 ml.
Date of Collection :- 18.06.2021
Client reference :- Sample collected by Laboratory Staff.
Packing of sample :- Sample filled in P.P. and Glass Bottle.
Source of sample :- from Tap of Jawahar Navodaya Vidyalaya,
Sector 25 (West), Chandigarh


S. No.	Examination	Quality Standard	Units	Results
1.	Turbidity	<1.0	N.T.U	0.9
2.	pH	7.0-8.5	----	7.65
3.	Residual Chlorine	0.2 - 0.4	mg/L	0.2
4.	Total Alkalinity (as CaCO ₃)	200	-do-	96
5.	Total Hardness (as CaCO ₃)	200	-do-	78
6.	Chlorides (as Cl)	200	-do-	06
7.	Free & Saline Ammonia	Nil	-do-	Nil
8.	Total Dissolved Solids	500	-do-	150
9.	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received receipt No.06/2021-22/028065, dated 17.06.2021, Amount Rs.3300/-

Note:- **Water is fit for drinking.**

Lab. No. MCPHL/21/ 255L

Dated:-21.06.2021


Chemist.
MCPH Laboratory
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No.2,
Chandigarh.
21/6/21